



DAP-PL-1524.23

Durch die DAP Deutsches Akkreditierungssystem Prüfwesen GmbH
akkreditiertes Prüflaboratorium

Zertifiziert nach DIN EN ISO 9001/14001

LGA-Zertifikat Nr. 7391275-02z

Dem Hersteller:

TECE GmbH
Hollefeldstraße 57
48282 Emsdetten

und Herstellwerk:

wie vor

wird bescheinigt, dass die Prüfung des nachfolgend beschriebenen Bauprodukts:

Wandeinbau Spülkasten aus Kunststoff

TECE, Nr.: S4

Füllventil: F1

Füllventil: F3

Spüleinrichtung: TECE

Prüfhöhe – Spülrohr: 95 mm

Spülwasservolumen: 6,0 l / 9,0 l

und Kleinmengenspülung (2-Tasten)

die Anforderungen folgender Norm erfüllt hat:

DIN 19542: 1984-10

entsprechend Bauregelliste A Teil 1,
Ifd. Nr. 12.2.9

Bei Verwendung der Spülrohr-Prüfhöhe von 90 mm wird empfohlen den Spülkasten nur mit Klosettbecken zu kombinieren, die ein Nachspülwasservolumen von $V_N \geq 3,00$ l haben.

Die Einzelergebnisse der durchgeführten Prüfung sind im LGA-Prüfbericht Nr. 7391275-02 dargestellt.

Dieses Zertifikat ist gültig bis 30.04.2014.

Würzburg, 27.04.2009

LGA QualiTest GmbH
Sanitär- und Abscheidetechnik

Dipl.-Ing. (FH) Arnold
Fachzentrumsleiter

H:\Datad\QIWQSAT\Zeugnisse\2009\7391275-02z.doc

The Manufacturer:

TECE GmbH
Hollefeldstraße 57
48282 Emsdetten

and Production plant:

as above

is attested, that the following described building product:

Concealed flushing cistern of plastic

TECE, no.: S4

Inlet valve: F1

Inlet valve: F3

Flushing device: TECE

test height – flush pipe: 95 mm

flush water volume: 6,0 l / 9,0 l

and reduced flushing volume (2-push buttons)

has fulfilled the requirements according to the following standard:

DIN 19542: 1984-10

according to Bauregelliste A Teil 1,
Ifd. Nr. 12.2.9

Using the test height (flush pipe) of 90 mm it is recommended to combine the cistern only with WC-pans, having an after flush volume of $V_N \geq 3,00$ l.

The detailed results of the test are shown in the test report no. 7391275-02 of the LGA.

This certificate is valid until 30.04.2014.



Seite 1 von 1
Sitz und Registergericht Nürnberg HRB 20544
Geschäftsführer: Hans-Hermann Ueffing,
Michael F. Jungnitsch